

Discovery School at Four Corners

DELETE FACILITY

Town: **GREENFIELD** DOE ID #: **01140025**

- [Notifications](#)
- [Sample Locations](#)
- [Downloads](#)
- [Uploads](#)

Listed below are the sample locations for **Discovery School at Four Corners**. If there are no locations listed, or to add a new sample location, click on the button "Add New Sample Location" below. To edit a location's description click in "Edit Location" in the corresponding sample location.

[Add New Sample Location](#)

[Show All Locations](#) [Show Active Locations Only](#) [Show Deleted Locations Only](#)

Location ID	Type	Location Description	Most Recent Sampling
001P	Kitchen Faucet, Cold	Food prep sink, kitchen	LEAD: 0.0013 MG/L (1/21/2017) COPPER: 0.55 MG/L (1/21/2017)
001F	Kitchen Faucet, Cold	Food prep sink, kitchen	LEAD: 0.00080 MG/L (1/21/2017) COPPER: 0.40 MG/L (1/21/2017)
002P	Water Cooler (Chiller Unit)	Cafeteria cooler, left	LEAD: 0.0017 MG/L (1/21/2017) COPPER: 0.46 MG/L (1/21/2017)
002F	Water Cooler (Chiller Unit)	Cafeteria cooler, left	LEAD: 0.0032 MG/L (1/21/2017) COPPER: 0.58 MG/L (1/21/2017)
003P	Water Cooler (Chiller Unit)	Cafeteria cooler, right	LEAD: 0.0028 MG/L (1/21/2017) COPPER: 0.53 MG/L (1/21/2017)
003F	Water Cooler (Chiller Unit)	Cafeteria cooler, right	LEAD: 0.0019 MG/L (1/21/2017) COPPER: 0.37 MG/L (1/21/2017)

004P	Water Cooler (Chiller Unit)	Library cooler	LEAD: 0.00052 MG/L (1/21/2017) COPPER: 0.41 MG/L (1/21/2017)
004F	Water Cooler (Chiller Unit)	Library cooler	LEAD: 0.00056 MG/L (1/21/2017) COPPER: 0.32 MG/L (1/21/2017)
005P	Drinking Water Bubblers	Room 30	LEAD: 0.0076 MG/L (1/21/2017) COPPER: 0.44 MG/L (1/21/2017)
006P	Classroom Faucet	Room 30	LEAD: 0.0048 MG/L (1/21/2017) COPPER: 0.24 MG/L (1/21/2017)
006F	Classroom Faucet	Room 30	LEAD: 0.0052 MG/L (1/21/2017) COPPER: 0.27 MG/L (1/21/2017)
007P	Drinking Water Bubblers	Room 29	LEAD: 0.0038 MG/L (1/21/2017) COPPER: 0.48 MG/L (1/21/2017)
008P	Classroom Faucet	Room 29	LEAD: 0.0014 MG/L (1/21/2017) COPPER: 0.26 MG/L (1/21/2017)
008F	Classroom Faucet	Room 29	LEAD: 0.00080 MG/L (1/21/2017) COPPER: 0.21 MG/L (1/21/2017)
009P	Drinking Water Bubblers	Room 28	LEAD: 0.0041 MG/L (1/21/2017) COPPER: 0.51 MG/L (1/21/2017)
010P	Classroom Faucet	Room 28	LEAD: 0.0087 MG/L (1/21/2017) COPPER: 0.43 MG/L (1/21/2017)
010F	Classroom Faucet	Room 28	LEAD: 0.00086 MG/L (1/21/2017) COPPER: 0.33 MG/L (1/21/2017)
011P	Drinking Water Bubblers	Room 27	LEAD: 0.0037 MG/L (1/21/2017) COPPER: 0.62 MG/L (1/21/2017)
012P	Classroom Faucet	Room 27	LEAD: 0.0026 MG/L (1/21/2017) COPPER: 0.45 MG/L (1/21/2017)

012F	Classroom Faucet	Room 27	LEAD: 0.00069 MG/L (1/21/2017) COPPER: 0.37 MG/L (1/21/2017)
013P	Drinking Water Bubblers	Room 26	LEAD: 0.0048 MG/L (1/21/2017) COPPER: 0.41 MG/L (1/21/2017)
014P	Classroom Faucet	Room 26	LEAD: 0.0051 MG/L (1/21/2017) COPPER: 0.27 MG/L (1/21/2017)
014F	Classroom Faucet	Room 26	LEAD: 0.00088 MG/L (1/21/2017) COPPER: 0.23 MG/L (1/21/2017)
015P	Drinking Water Bubblers	Room 25	LEAD: 0.0017 MG/L (1/21/2017) COPPER: 0.39 MG/L (1/21/2017)
016P	Classroom Faucet	Room 25	LEAD: 0.0019 MG/L (1/21/2017) COPPER: 0.20 MG/L (1/21/2017)
016F	Classroom Faucet	Room 25	LEAD: 0.00058 MG/L (1/21/2017) COPPER: 0.19 MG/L (1/21/2017)
017P	Drinking Water Bubblers	Room 24	LEAD: 0.0089 MG/L (1/21/2017) COPPER: 0.35 MG/L (1/21/2017)
018P	Classroom Faucet	Room 24	LEAD: 0.0032 MG/L (1/21/2017) COPPER: 0.16 MG/L (1/21/2017)
018F	Classroom Faucet	Room 24	LEAD: 0.00072 MG/L (1/21/2017) COPPER: 0.16 MG/L (1/21/2017)
019P	Drinking Water Bubblers	Room 23	LEAD: 0.0021 MG/L (1/21/2017) COPPER: 0.35 MG/L (1/21/2017)
020P	Classroom Faucet	Room 23	LEAD: 0.0011 MG/L (1/21/2017) COPPER: 0.20 MG/L (1/21/2017)
020F	Classroom Faucet	Room 23	LEAD: ND (1/21/2017) COPPER: 0.18 MG/L (1/21/2017)

021P	Nurse's Office Sink	Nurse's office	LEAD: 0.0017 MG/L (1/21/2017) COPPER: 0.19 MG/L (1/21/2017)
021F	Nurse's Office Sink	Nurse's office	LEAD: 0.00070 MG/L (1/21/2017) COPPER: 0.16 MG/L (1/21/2017)
022P	Bathroom Faucet	Teacher's Room bathroom	LEAD: 0.0041 MG/L (1/21/2017) COPPER: 0.23 MG/L (1/21/2017)
022F	Bathroom Faucet	Teacher's Room bathroom	LEAD: ND (1/21/2017) COPPER: 0.14 MG/L (1/21/2017)
023P	Drinking Water Bubblers	Room 17	LEAD: 0.0045 MG/L (1/21/2017) COPPER: 0.63 MG/L (1/21/2017)
024P	Classroom Faucet	Room 17	LEAD: 0.0014 MG/L (1/21/2017) COPPER: 0.36 MG/L (1/21/2017)
024F	Classroom Faucet	Room 17	LEAD: ND (1/21/2017) COPPER: 0.32 MG/L (1/21/2017)
025P	Drinking Water Bubblers	Room 16	LEAD: 0.0027 MG/L (1/21/2017) COPPER: 0.39 MG/L (1/21/2017)
026P	Classroom Faucet	Room 16	LEAD: 0.0045 MG/L (1/21/2017) COPPER: 0.32 MG/L (1/21/2017)
026F	Classroom Faucet	Room 16	LEAD: 0.0011 MG/L (1/21/2017) COPPER: 0.22 MG/L (1/21/2017)
027P	Drinking Water Bubblers	Room 14	LEAD: 0.0017 MG/L (1/21/2017) COPPER: 1.2 MG/L (1/21/2017)
028P	Classroom Faucet	Room 14	LEAD: 0.00055 MG/L (1/21/2017) COPPER: 0.87 MG/L (1/21/2017)
028F	Classroom Faucet	Room 14	LEAD: 0.00050 MG/L (1/21/2017) COPPER: 0.46 MG/L (1/21/2017)

029P	Drinking Water bubbler	Art Room 12	LEAD: 0.010 MG/L (1/21/2017) COPPER: 0.56 MG/L (1/21/2017)
030P	Classroom Faucet	Art Room 12	LEAD: 0.0073 MG/L (1/21/2017) COPPER: 0.48 MG/L (1/21/2017)
030F	Classroom Faucet	Art Room 12	LEAD: 0.00051 MG/L (1/21/2017) COPPER: 0.49 MG/L (1/21/2017)
031P	Drinking Water bubbler	Room 13	LEAD: 0.0085 MG/L (1/21/2017) COPPER: 0.76 MG/L (1/21/2017)
032P	Classroom Faucet	Room 13	LEAD: 0.0021 MG/L (1/21/2017) COPPER: 0.34 MG/L (1/21/2017)
032F	Classroom Faucet	Room 13	LEAD: ND (1/21/2017) COPPER: 0.48 MG/L (1/21/2017)
033P	Drinking Water bubbler	Room 11	LEAD: 0.017 MG/L (1/21/2017) COPPER: 0.61 MG/L (1/21/2017)
034P	Classroom Faucet	Room 11	LEAD: 0.0013 MG/L (1/21/2017) COPPER: 0.52 MG/L (1/21/2017)
034F	Classroom Faucet	Room 11	LEAD: ND (1/21/2017) COPPER: 0.45 MG/L (1/21/2017)
035P	Drinking Water bubbler	Room 10	LEAD: 0.00093 MG/L (1/21/2017) COPPER: 1.3 MG/L (1/21/2017)
036P	Classroom Faucet	Room 10	LEAD: 0.0012 MG/L (1/21/2017) COPPER: 0.91 MG/L (1/21/2017)
036F	Classroom Faucet	Room 10	LEAD: ND (1/21/2017) COPPER: 0.40 MG/L (1/21/2017)
037P	Drinking Water bubbler	Room 9	LEAD: 0.0039 MG/L (1/21/2017) COPPER: 0.69 MG/L (1/21/2017)

038P	Classroom Faucet	Room 9	LEAD: 0.0037 MG/L (1/21/2017) COPPER: 0.23 MG/L (1/21/2017)
038F	Classroom Faucet	Room 9	LEAD: ND (1/21/2017) COPPER: 0.20 MG/L (1/21/2017)
039P	Drinking Water Bubbler	Room 6	LEAD: 0.0030 MG/L (1/21/2017) COPPER: 0.61 MG/L (1/21/2017)
040P	Classroom Faucet	Room 6	LEAD: 0.0010 MG/L (1/21/2017) COPPER: 0.15 MG/L (1/21/2017)
040F	Classroom Faucet	Room 6	LEAD: ND (1/21/2017) COPPER: 0.18 MG/L (1/21/2017)
041P	Drinking Water Bubbler	Hall bubbler by gym	LEAD: ND (1/21/2017) COPPER: 0.32 MG/L (1/21/2017)
041F	Drinking Water Bubbler	Hall bubbler by gym	LEAD: ND (1/21/2017) COPPER: 0.36 MG/L (1/21/2017)