

# Greenfield Middle

DELETE FACILITY

Town: **GREENFIELD** DOE ID #: **01140305**

- [Notifications](#)
- Sample Locations
- [Downloads](#)
- [Uploads](#)

Listed below are the sample locations for **Greenfield Middle**. If there are no locations listed, or to add a new sample location, click on the button "Add New Sample Location" below. To edit a location's description click in "Edit Location" in the corresponding sample location.

[Add New Sample Location](#)

[Show All Locations](#) [Show Active Locations Only](#) [Show Deleted Locations Only](#)

Location ID	Type	Location Description	Most Recent Sampling
001P	Drinking Water bubbler	Ground floor hall bubbler by gym left	LEAD: ND (1/21/2017) COPPER: 0.48 MG/L (1/21/2017)
002P	Drinking Water bubbler	Ground floor hall bubbler by gym right	LEAD: 0.00055 MG/L (1/21/2017) COPPER: 0.61 MG/L (1/21/2017)
002F	Drinking Water bubbler	Ground floor hall bubbler by gym right	LEAD: 0.00056 MG/L (1/21/2017) COPPER: 0.46 MG/L (1/21/2017)
003P	Water Cooler (Chiller Unit)	Cooler cafeteria left	LEAD: ND (1/21/2017) COPPER: 0.69 MG/L (1/21/2017)
003F	Water Cooler (Chiller Unit)	Cooler cafeteria left	LEAD: ND (1/21/2017) COPPER: 0.71 MG/L (1/21/2017)
004P	Water Cooler (Chiller Unit)	Cooler cafeteria right	LEAD: ND (1/21/2017) COPPER: 0.69 MG/L (1/21/2017)

004F	Water Cooler (Chiller Unit)	Cooler cafeteria right	LEAD: ND (1/21/2017) COPPER: 0.64 MG/L (1/21/2017)
005P	Kitchen Kettle, Cold	Square Kitchen Kettle	LEAD: 0.0078 MG/L (1/21/2017) COPPER: 0.51 MG/L (1/21/2017)
005F	Kitchen Kettle, Cold	Square Kitchen Kettle	LEAD: 0.0011 MG/L (1/21/2017) COPPER: 0.67 MG/L (1/21/2017)
006P	Kitchen Kettle, Cold	Kitchen kettle	LEAD: 0.0035 MG/L (1/21/2017) COPPER: 0.91 MG/L (1/21/2017)
006F	Kitchen Kettle, Cold	Kitchen kettle	LEAD: ND (1/21/2017) COPPER: 0.77 MG/L (1/21/2017)
007P	Kitchen Faucet, Cold	Kitchen single basin sink (handwash)	LEAD: 0.0026 MG/L (1/21/2017) COPPER: 0.88 MG/L (1/21/2017)
007F	Kitchen Faucet, Cold	Kitchen single basin sink (handwash)	LEAD: ND (1/21/2017) COPPER: 0.56 MG/L (1/21/2017)
008P	Kitchen Faucet, Cold	Food prep sink- double basin	LEAD: 0.0010 MG/L (1/21/2017) COPPER: 0.55 MG/L (1/21/2017)
008F	Kitchen Faucet, Cold	Food prep sink- double basin	LEAD: ND (1/21/2017) COPPER: 0.54 MG/L (1/21/2017)
009P	Kitchen Faucet, Cold	Kitchen three bay sink left	LEAD: 0.0010 MG/L (1/21/2017) COPPER: 0.59 MG/L (1/21/2017)
009F	Kitchen Faucet, Cold	Kitchen three bay sink left	LEAD: ND (1/21/2017) COPPER: 0.53 MG/L (1/21/2017)
010P	Kitchen Faucet, Cold	Kitchen three bay sink right	LEAD: 0.0010 MG/L (1/21/2017) COPPER: 0.53 MG/L (1/21/2017)
010F	Kitchen Faucet, Cold	Kitchen three bay sink right	LEAD: ND (1/21/2017) COPPER: 0.49 MG/L (1/21/2017)

011P	Classroom Faucet	Special Ed G-17	LEAD: 0.00090 MG/L (1/21/2017) COPPER: <b>2.3 MG/L (1/21/2017)</b>
011F	Classroom Faucet	Special Ed G-17	LEAD: ND (1/21/2017) COPPER: <b>1.5 MG/L (1/21/2017)</b>
012P	Classroom Faucet	Special Ed G-18 (G-13 written on door casing)	LEAD: 0.0021 MG/L (1/21/2017) COPPER: <b>1.6 MG/L (1/21/2017)</b>
012F	Classroom Faucet	Special Ed G-18 (G-13 written on door casing)	LEAD: 0.0021 MG/L (1/21/2017) COPPER: <b>1.4 MG/L (1/21/2017)</b>
013P	Classroom Faucet	Room 101	LEAD: <b>0.059 MG/L (1/21/2017)</b> COPPER: <b>2.2 MG/L (1/21/2017)</b>
013F	Classroom Faucet	Room 101	LEAD: 0.0017 MG/L (1/21/2017) COPPER: 0.44 MG/L (1/21/2017)
014P	Classroom Faucet	Room 102	LEAD: 0.0028 MG/L (1/21/2017) COPPER: 0.98 MG/L (1/21/2017)
014F	Classroom Faucet	Room 102	LEAD: ND (1/21/2017) COPPER: 0.39 MG/L (1/21/2017)
015P	Classroom Faucet	Room 104	LEAD: 0.0035 MG/L (1/21/2017) COPPER: 0.29 MG/L (1/21/2017)
015F	Classroom Faucet	Room 104	LEAD: 0.00078 MG/L (1/21/2017) COPPER: 0.63 MG/L (1/21/2017)
016P	Classroom Faucet	Room 124 computer lab	LEAD: 0.0087 MG/L (1/21/2017) COPPER: 0.46 MG/L (1/21/2017)
016F	Classroom Faucet	Room 124 computer lab	LEAD: 0.0042 MG/L (1/21/2017) COPPER: 0.71 MG/L (1/21/2017)
017P	Drinking Water Bubbler	Hall bubbler by Room 108 left	LEAD: 0.0041 MG/L (1/21/2017) COPPER: 1.2 MG/L (1/21/2017)

018P	Drinking Water bubbler	Hall bubbler by 108 right	LEAD: 0.0025 MG/L (1/21/2017) COPPER: 1.0 MG/L (1/21/2017)
018F	Drinking Water bubbler	Hall bubbler by 108 right	LEAD: 0.0012 MG/L (1/21/2017) COPPER: 0.78 MG/L (1/21/2017)
019P	Classroom Faucet	Room 121	LEAD: 0.0082 MG/L (1/21/2017) COPPER: <b>2.0 MG/L (1/21/2017)</b>
019F	Classroom Faucet	Room 121	LEAD: 0.00080 MG/L (1/21/2017) COPPER: 0.41 MG/L (1/21/2017)
020P	Other	Admin office formerly 147	LEAD: 0.0017 MG/L (1/21/2017) COPPER: <b>2.4 MG/L (1/21/2017)</b>
020F	Other	Admin office formerly 147	LEAD: 0.0019 MG/L (1/21/2017) COPPER: 0.38 MG/L (1/21/2017)
021P	Other	Conference Room (formerly Room 15)	LEAD: 0.0047 MG/L (1/21/2017) COPPER: <b>2.1 MG/L (1/21/2017)</b>
021F	Other	Conference Room (formerly Room 15)	LEAD: 0.0013 MG/L (1/21/2017) COPPER: 0.63 MG/L (1/21/2017)
022P	Other	Assistant Superintendent's Office	LEAD: 0.0038 MG/L (1/21/2017) COPPER: 0.89 MG/L (1/21/2017)
022F	Other	Assistant Superintendent's Office	LEAD: 0.0017 MG/L (1/21/2017) COPPER: 0.55 MG/L (1/21/2017)
023P	Drinking Water bubbler	Hall bubbler by Assist. Super left	LEAD: 0.0015 MG/L (1/21/2017) COPPER: <b>1.9 MG/L (1/21/2017)</b>
024P	Drinking Water bubbler	Hall bubbler by Assist. Super right	LEAD: 0.00057 MG/L (1/21/2017) COPPER: 1.1 MG/L (1/21/2017)
024F	Drinking Water bubbler	Hall bubbler by Assist. Super right	LEAD: 0.00089 MG/L (1/21/2017) COPPER: 0.54 MG/L (1/21/2017)

025P	Classroom Faucet	Room 112-second sink only	LEAD: 0.0051 MG/L (1/21/2017) COPPER: 0.50 MG/L (1/21/2017)
025F	Classroom Faucet	Room 112-second sink only	LEAD: 0.0059 MG/L (1/21/2017) COPPER: <b>2.0 MG/L (1/21/2017)</b>
026P	Classroom Faucet	Room 111 faucet	LEAD: 0.0021 MG/L (1/21/2017) COPPER: <b>2.2 MG/L (1/21/2017)</b>
026F	Classroom Faucet	Room 111 faucet	LEAD: 0.00053 MG/L (1/21/2017) COPPER: <b>1.7 MG/L (1/21/2017)</b>
027P	Classroom Faucet	Room 110	LEAD: 0.0024 MG/L (1/21/2017) COPPER: <b>3.7 MG/L (1/21/2017)</b>
027F	Classroom Faucet	Room 110	LEAD: 0.00058 MG/L (1/21/2017) COPPER: <b>1.5 MG/L (1/21/2017)</b>
028P	Classroom Faucet	Art Room 129 left	LEAD: 0.0037 MG/L (1/21/2017) COPPER: 0.94 MG/L (1/21/2017)
028F	Classroom Faucet	Art Room 129 left	LEAD: 0.00084 MG/L (1/21/2017) COPPER: 0.52 MG/L (1/21/2017)
029P	Classroom Faucet	Art Room 129 middle	LEAD: 0.0048 MG/L (1/21/2017) COPPER: 0.59 MG/L (1/21/2017)
029F	Classroom Faucet	Art Room 129 middle	LEAD: 0.0014 MG/L (1/21/2017) COPPER: 0.51 MG/L (1/21/2017)
030P	Classroom Faucet	Art Room 129 right	LEAD: 0.0053 MG/L (1/21/2017) COPPER: 0.53 MG/L (1/21/2017)
030F	Classroom Faucet	Art Room 129 right	LEAD: 0.0011 MG/L (1/21/2017) COPPER: 0.49 MG/L (1/21/2017)
031P	Classroom Faucet	Sewing Room 130	LEAD: 0.0033 MG/L (1/21/2017) COPPER: 0.051 MG/L (1/21/2017)

031F	Classroom Faucet	Sewing Room 130	LEAD: 0.00083 MG/L (1/21/2017) COPPER: 0.52 MG/L (1/21/2017)
032P	Classroom Faucet	Music Room 227 (in closet)	LEAD: <b>0.050 MG/L (1/21/2017)</b> COPPER: 0.056 MG/L (1/21/2017)
032F	Classroom Faucet	Music Room 227 (in closet)	LEAD: <b>0.042 MG/L (1/21/2017)</b> COPPER: 0.26 MG/L (1/21/2017)
033P	Classroom Faucet	Room 210 faucet	LEAD: 0.0038 MG/L (1/21/2017) COPPER: 0.58 MG/L (1/21/2017)
033F	Classroom Faucet	Room 210 faucet	LEAD: 0.00070 MG/L (1/21/2017) COPPER: 1.1 MG/L (1/21/2017)
034P	Classroom Faucet	Room 211 faucet	LEAD: 0.0017 MG/L (1/21/2017) COPPER: <b>1.4 MG/L (1/21/2017)</b>
034F	Classroom Faucet	Room 211 faucet	LEAD: 0.00061 MG/L (1/21/2017) COPPER: 0.75 MG/L (1/21/2017)
035P	Classroom Faucet	Room 214 faucet	LEAD: 0.0026 MG/L (1/21/2017) COPPER: <b>2.0 MG/L (1/21/2017)</b>
035F	Classroom Faucet	Room 214 faucet	LEAD: 0.0015 MG/L (1/21/2017) COPPER: 0.65 MG/L (1/21/2017)
036P	Drinking Water Bubbler	Hall bubbler by room 214 left	LEAD: ND (1/21/2017) COPPER: 0.85 MG/L (1/21/2017)
037P	Drinking Water Bubbler	Hall bubbler by room 214 right	LEAD: ND (1/21/2017) COPPER: 0.79 MG/L (1/21/2017)
037F	Drinking Water Bubbler	Hall bubbler by room 214 right	LEAD: 0.00055 MG/L (1/21/2017) COPPER: 0.68 MG/L (1/21/2017)
038P	Classroom Faucet	Room 215	LEAD: 0.0019 MG/L (1/21/2017) COPPER: 0.87 MG/L (1/21/2017)

038F	Classroom Faucet	Room 215	LEAD: 0.00081 MG/L (1/21/2017) COPPER: 0.95 MG/L (1/21/2017)
039P	Classroom Faucet	Room 216	LEAD: 0.0044 MG/L (1/21/2017) COPPER: 0.76 MG/L (1/21/2017)
039F	Classroom Faucet	Room 216	LEAD: ND (1/21/2017) COPPER: 0.50 MG/L (1/21/2017)
040P	Other	Teacher's Room 220	LEAD: 0.0016 MG/L (1/21/2017) COPPER: 1.2 MG/L (1/21/2017)
040F	Other	Teacher's Room 220	LEAD: ND (1/21/2017) COPPER: 0.45 MG/L (1/21/2017)
041P	Other	Principal's Office	LEAD: 0.0044 MG/L (1/21/2017) COPPER: 0.47 MG/L (1/21/2017)
041F	Other	Principal's Office	LEAD: ND (1/21/2017) COPPER: 0.42 MG/L (1/21/2017)
042P	Nurse's Office Sink	Nurse Station	LEAD: 0.0020 MG/L (1/21/2017) COPPER: 1.3 MG/L (1/21/2017)
042F	Nurse's Office Sink	Nurse Station	LEAD: 0.00075 MG/L (1/21/2017) COPPER: 0.47 MG/L (1/21/2017)
043P	Nurse's Office Sink	Nurse Restroom	LEAD: 0.0019 MG/L (1/21/2017) COPPER: 1.0 MG/L (1/21/2017)
043F	Nurse's Office Sink	Nurse Restroom	LEAD: ND (1/21/2017) COPPER: 0.65 MG/L (1/21/2017)
044P	Classroom Faucet	Room 232 faucet	LEAD: 0.0029 MG/L (1/21/2017) COPPER: <b>1.8 MG/L (1/21/2017)</b>
044F	Classroom Faucet	Room 232 faucet	LEAD: 0.00070 MG/L (1/21/2017) COPPER: 0.49 MG/L (1/21/2017)

045P	Other	Library Work Room	LEAD: 0.013 MG/L (1/21/2017) COPPER: 0.42 MG/L (1/21/2017)
045F	Other	Library Work Room	LEAD: 0.0030 MG/L (1/21/2017) COPPER: 0.78 MG/L (1/21/2017)
046P	Drinking Water Bubbler	Hall bubbler by room 232 left	LEAD: ND (1/21/2017) COPPER: <b>1.7 MG/L (1/21/2017)</b>
047P	Drinking Water Bubbler	Hall bubbler by room 232 right	LEAD: ND (1/21/2017) COPPER: 0.86 MG/L (1/21/2017)
047F	Drinking Water Bubbler	Hall bubbler by room 232 right	LEAD: ND (1/21/2017) COPPER: 0.48 MG/L (1/21/2017)
048P	Classroom Faucet	Room 208	LEAD: 0.0019 MG/L (1/21/2017) COPPER: 0.93 MG/L (1/21/2017)
048F	Classroom Faucet	Room 208	LEAD: ND (1/21/2017) COPPER: 0.44 MG/L (1/21/2017)
049P	Classroom Faucet	Room 207	LEAD: 0.00091 MG/L (1/21/2017) COPPER: 0.50 MG/L (1/21/2017)
049F	Classroom Faucet	Room 207	LEAD: ND (1/21/2017) COPPER: 0.87 MG/L (1/21/2017)
050P	Classroom Faucet	Room 204	LEAD: 0.0017 MG/L (1/21/2017) COPPER: 1.2 MG/L (1/21/2017)
050F	Classroom Faucet	Room 204	LEAD: 0.00051 MG/L (1/21/2017) COPPER: 0.58 MG/L (1/21/2017)
051P	Classroom Faucet	Room 203, 2nd sink from left only	LEAD: <b>0.055 MG/L (1/21/2017)</b> COPPER: 1.1 MG/L (1/21/2017)
051F	Classroom Faucet	Room 203, 2nd sink from left only	LEAD: 0.0013 MG/L (1/21/2017) COPPER: 0.45 MG/L (1/21/2017)

052P	Classroom Faucet	Room 202	LEAD: 0.0071 MG/L (1/21/2017) COPPER: 0.83 MG/L (1/21/2017)
052F	Classroom Faucet	Room 202	LEAD: 0.00056 MG/L (1/21/2017) COPPER: 0.43 MG/L (1/21/2017)
053P	Classroom Faucet	Room 201	LEAD: 0.0028 MG/L (1/21/2017) COPPER: 0.80 MG/L (1/21/2017)
053F	Classroom Faucet	Room 201	LEAD: ND (1/21/2017) COPPER: 0.45 MG/L (1/21/2017)
054P	Classroom Faucet	Room 310	LEAD: <b>0.31 MG/L (1/21/2017)</b> COPPER: <b>11 MG/L (1/21/2017)</b>
054F	Classroom Faucet	Room 310	LEAD: 0.0015 MG/L (1/21/2017) COPPER: 1.0 MG/L (1/21/2017)
055P	Classroom Faucet	Room 311	LEAD: 0.0050 MG/L (1/21/2017) COPPER: 0.23 MG/L (1/21/2017)
055F	Classroom Faucet	Room 311	LEAD: 0.00082 MG/L (1/21/2017) COPPER: 0.63 MG/L (1/21/2017)
056P	Classroom Faucet	Room 312, 2nd sink from left only	LEAD: <b>0.080 MG/L (1/21/2017)</b> COPPER: 0.41 MG/L (1/21/2017)
056F	Classroom Faucet	Room 312, 2nd sink from left only	LEAD: 0.011 MG/L (1/21/2017) COPPER: <b>1.6 MG/L (1/21/2017)</b>
057P	Classroom Faucet	Room 314 faucet	LEAD: 0.0031 MG/L (1/21/2017) COPPER: 0.91 MG/L (1/21/2017)
057F	Classroom Faucet	Room 314 faucet	LEAD: 0.0019 MG/L (1/21/2017) COPPER: 0.85 MG/L (1/21/2017)
058P	Classroom Faucet	Room 315 faucet	LEAD: 0.0084 MG/L (1/21/2017) COPPER: 0.41 MG/L (1/21/2017)

058F	Classroom Faucet	Room 315 faucet	LEAD: 0.0011 MG/L (1/21/2017) COPPER: 0.67 MG/L (1/21/2017)
059P	Classroom Faucet	Room 316 faucet	LEAD: 0.0028 MG/L (1/21/2017) COPPER: 0.48 MG/L (1/21/2017)
059F	Classroom Faucet	Room 316 faucet	LEAD: ND (1/21/2017) COPPER: 0.48 MG/L (1/21/2017)
060P	Drinking Water Bubblers	Hall bubbler by 314 left	LEAD: 0.00051 MG/L (1/21/2017) COPPER: <b>2.5 MG/L (1/21/2017)</b>
061P	Drinking Water Bubblers	Hall bubbler by 314 right	LEAD: ND (1/21/2017) COPPER: <b>2.0 MG/L (1/21/2017)</b>
061F	Drinking Water Bubblers	Hall bubbler by 314 right	LEAD: 0.00052 MG/L (1/21/2017) COPPER: 0.69 MG/L (1/21/2017)
062P	Classroom Faucet	Room 316 Not in Use	LEAD: No Sample Results Found COPPER: No Sample Results Found
062F	Classroom Faucet	Room 316 Not in Use	LEAD: No Sample Results Found COPPER: No Sample Results Found
063P	Other	Room 320 office	LEAD: 0.0011 MG/L (1/21/2017) COPPER: <b>1.4 MG/L (1/21/2017)</b>
063F	Other	Room 320 office	LEAD: 0.00062 MG/L (1/21/2017) COPPER: 0.50 MG/L (1/21/2017)
064P	Classroom Faucet	Room 330 faucet	LEAD: No Sample Results Found

			COPPER: No Sample Results Found
064F	Classroom Faucet	Room 330 faucet	LEAD: No Sample Results Found COPPER: No Sample Results Found
065P	Other	Room 321 office	LEAD: 0.0042 MG/L (1/21/2017) COPPER: <b>2.3 MG/L (1/21/2017)</b>
065F	Other	Room 321 office	LEAD: 0.00065 MG/L (1/21/2017) COPPER: 0.47 MG/L (1/21/2017)
066P	Classroom Faucet	Room 327	LEAD: 0.0017 MG/L (1/21/2017) COPPER: 0.88 MG/L (1/21/2017)
066F	Classroom Faucet	Room 327	LEAD: ND (1/21/2017) COPPER: 0.49 MG/L (1/21/2017)
067P	Classroom Faucet	Room 308 faucet	LEAD: 0.0015 MG/L (1/21/2017) COPPER: 1.1 MG/L (1/21/2017)
067F	Classroom Faucet	Room 308 faucet	LEAD: ND (1/21/2017) COPPER: 0.46 MG/L (1/21/2017)
068P	Drinking Water bubbler	Hall bubbler by room 321 left	LEAD: ND (1/21/2017) COPPER: <b>1.6 MG/L (1/21/2017)</b>
069P	Drinking Water bubbler	Hall bubbler by room 321 right	LEAD: ND (1/21/2017) COPPER: 0.84 MG/L (1/21/2017)
069F	Drinking Water bubbler	Hall bubbler by room 321 right	LEAD: ND (1/21/2017) COPPER: 0.53 MG/L (1/21/2017)
070P	Classroom Faucet	Room 304 faucet	LEAD: 0.00067 MG/L (1/21/2017) COPPER: <b>2.0 MG/L (1/21/2017)</b>

070F	Classroom Faucet	Room 304 faucet	LEAD: 0.00050 MG/L (1/21/2017) COPPER: 0.60 MG/L (1/21/2017)
071P	Classroom Faucet	Room 303 faucet	LEAD: 0.0012 MG/L (1/21/2017) COPPER: <b>2.7 MG/L (1/21/2017)</b>
071F	Classroom Faucet	Room 303 faucet	LEAD: 0.00064 MG/L (1/21/2017) COPPER: 0.93 MG/L (1/21/2017)
072P	Classroom Faucet	Room 302 faucet	LEAD: 0.0016 MG/L (1/21/2017) COPPER: 0.94 MG/L (1/21/2017)
072F	Classroom Faucet	Room 302 faucet	LEAD: ND (1/21/2017) COPPER: 0.47 MG/L (1/21/2017)
073P	Classroom Faucet	Room 301 faucet	LEAD: 0.0022 MG/L (1/21/2017) COPPER: 1.2 MG/L (1/21/2017)
073F	Classroom Faucet	Room 301 faucet	LEAD: ND (1/21/2017) COPPER: 0.51 MG/L (1/21/2017)
074P	Classroom Faucet	Faucet Room 212	LEAD: 0.015 MG/L (1/21/2017) COPPER: 0.20 MG/L (1/21/2017)
074F	Classroom Faucet	Faucet Room 212	LEAD: 0.0032 MG/L (1/21/2017) COPPER: 1.0 MG/L (1/21/2017)