

Newton School

DELETE FACILITY

Town: **GREENFIELD** DOE ID #: **01140035**

- [Notifications](#)
- [Sample Locations](#)
- [Downloads](#)
- [Uploads](#)

Listed below are the sample locations for **Newton School**. If there are no locations listed, or to add a new sample location, click on the button "Add New Sample Location" below. To edit a location's description click in "Edit Location" in the corresponding sample location.

[Add New Sample Location](#)

[Show All Locations](#) [Show Active Locations Only](#) [Show Deleted Locations Only](#)

Location ID	Type	Location Description	Most Recent Sampling
001P	Classroom Faucet	Room 113 faucet	LEAD: 0.0018 MG/L (1/21/2017) COPPER: 0.80 MG/L (1/21/2017)
001F	Classroom Faucet	Room 113 faucet	LEAD: ND (1/21/2017) COPPER: 0.71 MG/L (1/21/2017)
002P	Drinking Water Bubblers	Room 113 bubbler	LEAD: 0.0031 MG/L (1/21/2017) COPPER: 0.91 MG/L (1/21/2017)
003P	Classroom Faucet	Room 114 faucet	LEAD: 0.0029 MG/L (1/21/2017) COPPER: 0.70 MG/L (1/21/2017)
003F	Classroom Faucet	Room 114 faucet	LEAD: ND (1/21/2017) COPPER: 0.56 MG/L (1/21/2017)
004P	Drinking Water Bubblers	Room 114 bubbler	LEAD: 0.0025 MG/L (1/21/2017) COPPER: 0.82 MG/L (1/21/2017)

005P	Classroom Faucet	Room 115 faucet	LEAD: 0.0029 MG/L (1/21/2017) COPPER: 0.57 MG/L (1/21/2017)
005F	Classroom Faucet	Room 115 faucet	LEAD: 0.00054 MG/L (1/21/2017) COPPER: 0.53 MG/L (1/21/2017)
006P	Drinking Water Bubblers	Room 115 bubbler	LEAD: 0.0019 MG/L (1/21/2017) COPPER: 0.65 MG/L (1/21/2017)
007P	Classroom Faucet	Room 116 faucet	LEAD: 0.0013 MG/L (1/21/2017) COPPER: 0.71 MG/L (1/21/2017)
007F	Classroom Faucet	Room 116 faucet	LEAD: ND (1/21/2017) COPPER: 0.66 MG/L (1/21/2017)
008P	Drinking Water Bubblers	Room 116 bubbler	LEAD: 0.00088 MG/L (1/21/2017) COPPER: 0.80 MG/L (1/21/2017)
009P	Classroom Faucet	Room 117 faucet	LEAD: 0.0019 MG/L (1/21/2017) COPPER: 0.66 MG/L (1/21/2017)
009F	Classroom Faucet	Room 117 faucet	LEAD: 0.0012 MG/L (1/21/2017) COPPER: 0.37 MG/L (1/21/2017)
010P	Drinking Water Bubblers	Room 117 bubbler	LEAD: 0.0014 MG/L (1/21/2017) COPPER: 0.71 MG/L (1/21/2017)
011P	Classroom Faucet	Room 119 faucet	LEAD: 0.0015 MG/L (1/21/2017) COPPER: 1.1 MG/L (1/21/2017)
011F	Classroom Faucet	Room 119 faucet	LEAD: 0.00092 MG/L (1/21/2017) COPPER: 0.53 MG/L (1/21/2017)
012P	Drinking Water Bubblers	Room 119 bubbler	LEAD: 0.0080 MG/L (1/21/2017) COPPER: 0.86 MG/L (1/21/2017)
013P	Other	Tech Room (Miss Sherry's)	LEAD: 0.012 MG/L (1/21/2017) COPPER: 0.88 MG/L (1/21/2017)

013F	Other	Tech Room (Miss Sherry's)	LEAD: 0.00089 MG/L (1/21/2017) COPPER: 0.40 MG/L (1/21/2017)
014P	Water Cooler (Chiller Unit)	hall cooler by girls bathroom	LEAD: ND (1/21/2017) COPPER: 0.85 MG/L (1/21/2017)
014F	Water Cooler (Chiller Unit)	hall cooler by girls bathroom	LEAD: 0.00082 MG/L (1/21/2017) COPPER: 0.61 MG/L (1/21/2017)
015P	Classroom Faucet	Art Room 111 faucet	LEAD: 0.0015 MG/L (1/21/2017) COPPER: 0.55 MG/L (1/21/2017)
015F	Classroom Faucet	Art Room 111 faucet	LEAD: ND (1/21/2017) COPPER: 0.36 MG/L (1/21/2017)
016P	Drinking Water Bubbler	Art Room 111 bubbler	LEAD: 0.0034 MG/L (1/21/2017) COPPER: 0.74 MG/L (1/21/2017)
017P	Water Cooler (Chiller Unit)	Hall cooler outside kitchen	LEAD: ND (1/21/2017) COPPER: 1.1 MG/L (1/21/2017)
017F	Water Cooler (Chiller Unit)	Hall cooler outside kitchen	LEAD: 0.00059 MG/L (1/21/2017) COPPER: 0.97 MG/L (1/21/2017)
018P	Water Cooler (Chiller Unit)	Cooler in cafeteria left	LEAD: 0.00051 MG/L (1/21/2017) COPPER: 0.73 MG/L (1/21/2017)
018F	Water Cooler (Chiller Unit)	Cooler in cafeteria left	LEAD: 0.00066 MG/L (1/21/2017) COPPER: 0.83 MG/L (1/21/2017)
019P	Water Cooler (Chiller Unit)	Cooler in cafeteria right	LEAD: 0.00061 MG/L (1/21/2017) COPPER: 0.79 MG/L (1/21/2017)
019F	Water Cooler (Chiller Unit)	Cooler in cafeteria right	LEAD: ND (1/21/2017) COPPER: 0.62 MG/L (1/21/2017)
020P	Kitchen Faucet, Cold	Kitchen food sink double basin	LEAD: 0.00054 MG/L (1/21/2017) COPPER: 0.29 MG/L (1/21/2017)

020F	Kitchen Faucet, Cold	Kitchen food sink double basin	LEAD: ND (1/21/2017) COPPER: 0.38 MG/L (1/21/2017)
021P	Kitchen Faucet, Cold	Kitchen Food sink single basin	LEAD: 0.0032 MG/L (1/21/2017) COPPER: 0.39 MG/L (1/21/2017)
021F	Kitchen Faucet, Cold	Kitchen Food sink single basin	LEAD: ND (1/21/2017) COPPER: 0.40 MG/L (1/21/2017)
022P	Classroom Faucet	Room 108 faucet	LEAD: 0.00069 MG/L (1/21/2017) COPPER: 0.56 MG/L (1/21/2017)
022F	Classroom Faucet	Room 108 faucet	LEAD: ND (1/21/2017) COPPER: 0.40 MG/L (1/21/2017)
023P	Drinking Water Bubblers	Room 108 bubbler	LEAD: 0.0036 MG/L (1/21/2017) COPPER: 0.70 MG/L (1/21/2017)
024P	Nurse's Office Sink	Nurse Restroom	LEAD: 0.0017 MG/L (1/21/2017) COPPER: 0.59 MG/L (1/21/2017)
024F	Nurse's Office Sink	Nurse Restroom	LEAD: ND (1/21/2017) COPPER: 0.41 MG/L (1/21/2017)
025P	Other	"Storage" Room 107 faucet	LEAD: 0.011 MG/L (1/21/2017) COPPER: 0.64 MG/L (1/21/2017)
025F	Other	"Storage" Room 107 faucet	LEAD: 0.00065 MG/L (1/21/2017) COPPER: 0.43 MG/L (1/21/2017)
026P	Drinking Water Bubblers	"Storage" Room 107 bubbler	LEAD: 0.0052 MG/L (1/21/2017) COPPER: 0.92 MG/L (1/21/2017)
027P	Classroom Faucet	Room 106 faucet	LEAD: 0.0013 MG/L (1/21/2017) COPPER: 0.35 MG/L (1/21/2017)
027F	Classroom Faucet	Room 106 faucet	LEAD: ND (1/21/2017) COPPER: 0.41 MG/L (1/21/2017)

028P	Drinking Water Bubblers	Room 106 bubbler	LEAD: 0.0028 MG/L (1/21/2017) COPPER: 0.58 MG/L (1/21/2017)
029P	Water Cooler (Chiller Unit)	Hall cooler by main lobby	LEAD: ND (1/21/2017) COPPER: 0.20 MG/L (1/21/2017)
029F	Water Cooler (Chiller Unit)	Hall cooler by main lobby	LEAD: ND (1/21/2017) COPPER: 0.16 MG/L (1/21/2017)
030P	Other	Main office sink	LEAD: 0.0057 MG/L (1/21/2017) COPPER: 0.93 MG/L (1/21/2017)
030F	Other	Main office sink	LEAD: 0.0010 MG/L (1/21/2017) COPPER: 0.44 MG/L (1/21/2017)
031P	Drinking Water Bubblers	Gym bubbler	LEAD: 0.0010 MG/L (1/21/2017) COPPER: 0.80 MG/L (1/21/2017)
031F	Drinking Water Bubblers	Gym bubbler	LEAD: ND (1/21/2017) COPPER: 0.44 MG/L (1/21/2017)
032P	Water Cooler (Chiller Unit)	Hall cooler by room 105	LEAD: ND (1/21/2017) COPPER: 1.8 MG/L (1/21/2017)
032F	Water Cooler (Chiller Unit)	Hall cooler by room 105	LEAD: ND (1/21/2017) COPPER: 0.60 MG/L (1/21/2017)
033P	Classroom Faucet	Room 105 faucet	LEAD: 0.00050 MG/L (1/21/2017) COPPER: 0.68 MG/L (1/21/2017)
033F	Classroom Faucet	Room 105 faucet	LEAD: ND (1/21/2017) COPPER: 0.47 MG/L (1/21/2017)
034P	Drinking Water Bubblers	Room 105 bubbler	LEAD: 0.0011 MG/L (1/21/2017) COPPER: 0.81 MG/L (1/21/2017)
035P	Classroom Faucet	Room 104 faucet	LEAD: 0.0011 MG/L (1/21/2017) COPPER: 1.0 MG/L (1/21/2017)

035F	Classroom Faucet	Room 104 faucet	LEAD: ND (1/21/2017) COPPER: 0.91 MG/L (1/21/2017)
036P	Drinking Water Bubblers	Room 104 bubbler	LEAD: 0.0014 MG/L (1/21/2017) COPPER: 1.1 MG/L (1/21/2017)
037P	Classroom Faucet	Room 101 faucet	LEAD: 0.00069 MG/L (1/21/2017) COPPER: 0.31 MG/L (1/21/2017)
037F	Classroom Faucet	Room 101 faucet	LEAD: ND (1/21/2017) COPPER: 0.23 MG/L (1/21/2017)
038P	Drinking Water Bubblers	Room 101 bubbler	LEAD: 0.0013 MG/L (1/21/2017) COPPER: 0.69 MG/L (1/21/2017)
039P	Classroom Faucet	Room 102 faucet	LEAD: 0.0022 MG/L (1/21/2017) COPPER: 0.57 MG/L (1/21/2017)
039F	Classroom Faucet	Room 102 faucet	LEAD: 0.00067 MG/L (1/21/2017) COPPER: 0.53 MG/L (1/21/2017)
040P	Drinking Water Bubblers	Room 102 bubbler	LEAD: 0.0018 MG/L (1/21/2017) COPPER: 0.67 MG/L (1/21/2017)
041P	Classroom Faucet	Room 103 faucet	LEAD: 0.0021 MG/L (1/21/2017) COPPER: 0.58 MG/L (1/21/2017)
041F	Classroom Faucet	Room 103 faucet	LEAD: 0.00091 MG/L (1/21/2017) COPPER: 0.61 MG/L (1/21/2017)
042P	Drinking Water Bubblers	Room 103 bubbler	LEAD: 0.0025 MG/L (1/21/2017) COPPER: 0.88 MG/L (1/21/2017)